



**Analytes and Minimum Detectable Levels**

| <b>Parameter</b>                                | <b>MDL (mg/l)</b> |
|---|-------------------|
| <b>Metals</b>                                   |                   |
| First Draw Lead                                 | 0.001             |
| Flush Lead                                      | 0.001             |
| First Draw Copper                               | 0.004             |
| Flush Copper                                    | 0.004             |
| Calcium   | 2.0               |
| Magnesium                                       | 0.10              |
| <b>Inorganic Chemicals and Physical Factors</b> |                   |
| Alkalinity (Total as CaCO <sub>3</sub> )        | 20                |
| Chloride  | 5.0               |
| Hardness  | 10                |
| pH (Standard Units)                             | -                 |
| Sulfate   | 5.0               |
| Total Dissolved Solids                          | 20                |
| Corrosivity (Langelier Saturation Index)        | -                 |