

## POOL INSPECTION CHECKLIST (NSW)

Pools Built/Installed Before 01/09/2008

POOL FENCE		
Is your pool or boundary fence at least 1200mm high all the way around the pool area?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Are the gaps between the bottom of the fence and the ground no greater than 100mm?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
No potential hand holds or foot holds within 900mm of the top of the pool fence in any direction?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Are the gaps between the pool fence vertical rails or bars no greater than 100mm apart?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
If your pool fence has mesh or perforated material, are the holes no greater than 13mm?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Is your pool fence in good repair and fixed securely, with no damages?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
POOL GATES		
Does the pool gate open outwards away from the pool?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Does the pool gate self-close and self-latch from all open positions? The gate latch must be working well so that the gate is secure and, once closed, can't be pulled open.	<input type="checkbox"/> Yes	<input type="checkbox"/> No
If gate latch is on the outside, is the latch lever at least 1500mm above ground level?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
If gate latch is on the inside, is the latch lever at least 1200mm above ground level and at least 150mm below the top of the gate?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Are you aware that it is dangerous and against the law to prop the gate open?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
OTHER		
No climbable objects within 900mm on the outside and 300mm on the inside?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Is there a compliant CPR sign which can be easily read from a distance of 3 metres?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
If a wall forms part of the barrier, there are no openings greater than 100mm?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Windows in the pool area fitted with security screens or open no greater than 100mm?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Your pool fence must be clear of any objects such as BBQs, trees, rocks, shrubs and deckchairs that could help a small child climb over the fence?	<input type="checkbox"/> Yes	<input type="checkbox"/> No

The above checklist is to be used as a guide only. Please contact My Pool Safety Inspector for any specific advice you may require before your pool inspection.

## POOL INSPECTION CHECKLIST (NSW)

Pools Built/Installed Between 01/09/2008 & 30/04/2013

POOL FENCE		
Is your pool fence at least 1200mm high all the way around the pool area? If a boundary fence forms part of the pool fence, it must be at least 1800mm high?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Are the gaps between the bottom of the fence and the ground no greater than 100mm?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
No potential hand holds or foot holds within 900mm of the top of the pool fence in any direction?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Are the gaps between the pool fence vertical rails or bars no greater than 100mm apart?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
If your pool fence has mesh or perforated material, are the holes no greater than 13mm?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Is your pool fence in good repair and fixed securely, with no damages?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
POOL GATES		
Does the pool gate open outwards away from the pool?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Does the pool gate self-close and self-latch from all open positions? The gate latch must be working well so that the gate is secure and, once closed, can't be pulled open.	<input type="checkbox"/> Yes	<input type="checkbox"/> No
If gate latch is on the outside, is the latch lever at least 1500mm above ground level?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
If gate latch is on the inside, is the latch lever at least 1200mm above ground level and at least 150mm below the top of the gate?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Are you aware that it is dangerous and against the law to prop the gate open?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
OTHER		
No climbable objects within 900mm on the outside and 300mm on the inside?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Is there a compliant CPR sign which can be easily read from a distance of 3 metres?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
If a wall forms part of the barrier, there are no openings greater than 100mm?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Windows in the pool area fitted with security screens or open no greater than 100mm?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Your pool fence must be clear of any objects such as BBQs, trees, rocks, shrubs and deckchairs that could help a small child climb over the fence?	<input type="checkbox"/> Yes	<input type="checkbox"/> No

The above checklist is to be used as a guide only. Please contact My Pool Safety Inspector for any specific advice you may require before your pool inspection.

## POOL INSPECTION CHECKLIST (NSW)

Pools Built/Installed After 01/05/2013

POOL FENCE		
Is your pool fence at least 1200mm high all the way around the pool area? If a boundary fence forms part of the pool fence, it must be at least 1800mm high?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Are the gaps between the bottom of the fence and the ground no greater than 100mm?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
No potential hand holds or foot holds within 900mm of the top of the pool fence in any direction?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Are the gaps between the pool fence vertical rails or bars no greater than 100mm apart?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
If your pool fence has mesh or perforated material, are the holes no greater than 13mm?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Is your pool fence in good repair and fixed securely, with no damages?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
POOL GATES		
Does the pool gate open outwards away from the pool?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Does the pool gate self-close and self-latch from all open positions? The gate latch must be working well so that the gate is secure and, once closed, can't be pulled open.	<input type="checkbox"/> Yes	<input type="checkbox"/> No
If gate latch is on the outside, is the latch lever at least 1500mm above ground level?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
If gate latch is on the inside, is the latch lever at least 1200mm above ground level and at least 150mm below the top of the gate?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Are you aware that it is dangerous and against the law to prop the gate open?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
OTHER		
No climbable objects within 900mm on the outside and 300mm on the inside?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Is there a compliant CPR sign which can be easily read from a distance of 3 metres?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
If a wall forms part of the barrier, there are no openings greater than 100mm?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Windows in the pool area fitted with security screens or open no greater than 100mm?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Your pool fence must be clear of any objects such as BBQs, trees, rocks, shrubs and deckchairs that could help a small child climb over the fence?	<input type="checkbox"/> Yes	<input type="checkbox"/> No

The above checklist is to be used as a guide only. Please contact My Pool Safety Inspector for any specific advice you may require before your pool inspection.

## POOL INSPECTION CHECKLIST (NSW)

### Portable & Inflatable Pools

POOL FENCE		
Is your pool fence at least 1200mm high all the way around the pool area? If a boundary fence forms part of the pool fence, it must be at least 1800mm high?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Are the gaps between the bottom of the fence and the ground no greater than 100mm?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
No potential hand holds or foot holds within 900mm of the top of the pool fence in any direction?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Are the gaps between the pool fence vertical rails or bars no greater than 100mm apart?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
If your pool fence has mesh or perforated material, are the holes no greater than 13mm?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Is your pool fence in good repair and fixed securely, with no damages?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
POOL GATES		
Does the pool gate open outwards away from the pool?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Does the pool gate self-close and self-latch from all open positions? The gate latch must be working well so that the gate is secure and, once closed, can't be pulled open.	<input type="checkbox"/> Yes	<input type="checkbox"/> No
If gate latch is on the outside, is the latch lever at least 1500mm above ground level?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
If gate latch is on the inside, is the latch lever at least 1200mm above ground level and at least 150mm below the top of the gate?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Are you aware that it is dangerous and against the law to prop the gate open?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
OTHER		
No climbable objects within 900mm on the outside and 300mm on the inside?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Is there a compliant CPR sign which can be easily read from a distance of 3 metres?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
If a wall forms part of the barrier, there are no openings greater than 100mm?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Windows in the pool area fitted with security screens or open no greater than 100mm?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Your pool fence must be clear of any objects such as BBQs, trees, rocks, shrubs and deckchairs that could help a small child climb over the fence?	<input type="checkbox"/> Yes	<input type="checkbox"/> No

The above checklist is to be used as a guide only. Please contact My Pool Safety Inspector for any specific advice you may require before your pool inspection.



# POOL INSPECTION CHECKLIST (NSW)

Pools in Small Property 230m<sup>2</sup> or Less

Built/Installed with Door & Window as Barrier Before 01/07/2010

## DOORS

There is a latch on the door at least 1500mm above floor level on every door entering the pool area?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
There are no pet doors or openings to the pool area greater than 100mm?	<input type="checkbox"/> Yes	<input type="checkbox"/> No

## WINDOWS

The windows can only open to a maximum of 100mm? <b>OR</b>	<input type="checkbox"/> Yes	<input type="checkbox"/> No
The windows are totally covered by bars or a metal screen? <b>OR</b>	<input type="checkbox"/> Yes	<input type="checkbox"/> No
The height from the sill of the lowest opening panel of a window (to the pool area) is at least 1800mm from the floor?	<input type="checkbox"/> Yes	<input type="checkbox"/> No

The above checklist is to be used as a guide only. Please contact My Pool Safety Inspector for any specific advice you may require before your pool inspection.

[My Pool Safety Inspector Pty Ltd - Brisbane | Gold Coast | Sydney](#)  
[www.mypsi.com.au](http://www.mypsi.com.au) | [email@myspi.com.au](mailto:email@myspi.com.au)

# POOL INSPECTION CHECKLIST (NSW)

Pools in Small Property 230m<sup>2</sup> or Less

Built/Installed with a Pool Fence After 01/07/2010

POOL FENCE		
Is your pool fence at least 1200mm high all the way around the pool area?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
If a boundary fence forms part of the pool fence: Pools built before 01/09/2008 - it must be at least 1200mm high? Pools built after 01/09/2008 - it must be at least 1800mm high?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Are the gaps between the bottom of the fence and the ground no greater than 100mm?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
No potential hand holds or foot holds within 900mm of the top of the pool fence in any direction?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Are the gaps between the pool fence vertical rails or bars no greater than 100mm apart?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
If your pool fence has mesh or perforated material, are the holes no greater than 13mm?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Is your pool fence in good repair and fixed securely, with no damages?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
POOL GATES		
Does the pool gate open outwards away from the pool?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Does the pool gate self-close and self-latch from all open positions? The gate latch must be working well so that the gate is secure and, once closed, can't be pulled open.	<input type="checkbox"/> Yes	<input type="checkbox"/> No
If gate latch is on the outside, is the latch lever at least 1500mm above ground level?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
If gate latch is on the inside, is the latch lever at least 1200mm above ground level and at least 150mm below the top of the gate?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Are you aware that it is dangerous and against the law to prop the gate open?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
OTHER		
Is there a compliant CPR sign which can be easily read from a distance of 3 metres?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Your pool fence must be clear of any objects such as BBQs, trees, rocks, shrubs and deckchairs that could help a small child climb over the fence?	<input type="checkbox"/> Yes	<input type="checkbox"/> No

The above checklist is to be used as a guide only. Please contact My Pool Safety Inspector for any specific advice you may require before your pool inspection.



# POOL INSPECTION CHECKLIST (NSW)

Pools on a Property 2 Hectares or Larger

Built/Installed with Door & Window as Barrier Before 01/07/2010

DOORS		
There is a latch on the door at least 1500mm above floor level on every door entering the pool area?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
There are no pet doors or openings to the pool area greater than 100mm?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
WINDOWS		
The windows can only open to a maximum of 100mm? <b>OR</b>	<input type="checkbox"/> Yes	<input type="checkbox"/> No
The windows are totally covered by bars or a metal screen? <b>OR</b>	<input type="checkbox"/> Yes	<input type="checkbox"/> No
The height from the sill of the lowest opening panel of a window (to the pool area) is at least 1800mm from the floor?	<input type="checkbox"/> Yes	<input type="checkbox"/> No

The above checklist is to be used as a guide only. Please contact My Pool Safety Inspector for any specific advice you may require before your pool inspection.

[www.mypsi.com.au](http://www.mypsi.com.au) | [email@mypsi.com.au](mailto:email@mypsi.com.au)

# POOL INSPECTION CHECKLIST (NSW)

Pools on a Property 2 Hectares or Larger

Built/Installed with a Pool Fence After 01/07/2010

POOL FENCE		
Is your pool fence at least 1200mm high all the way around the pool area?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
If a boundary fence forms part of the pool fence: Pools built before 01/09/2008 - it must be at least 1200mm high? Pools built after 01/09/2008 - it must be at least 1800mm high?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Are the gaps between the bottom of the fence and the ground no greater than 100mm?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
No potential hand holds or foot holds within 900mm of the top of the pool fence in any direction?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Are the gaps between the pool fence vertical rails or bars no greater than 100mm apart?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
If your pool fence has mesh or perforated material, are the holes no greater than 13mm?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Is your pool fence in good repair and fixed securely, with no damages?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
POOL GATES		
Does the pool gate open outwards away from the pool?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Does the pool gate self-close and self-latch from all open positions? The gate latch must be working well so that the gate is secure and, once closed, can't be pulled open.	<input type="checkbox"/> Yes	<input type="checkbox"/> No
If gate latch is on the outside, is the latch lever at least 1500mm above ground level?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
If gate latch is on the inside, is the latch lever at least 1200mm above ground level and at least 150mm below the top of the gate?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Are you aware that it is dangerous and against the law to prop the gate open?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
OTHER		
Is there a compliant CPR sign which can be easily read from a distance of 3 metres?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Your pool fence must be clear of any objects such as BBQs, trees, rocks, shrubs and deckchairs that could help a small child climb over the fence?	<input type="checkbox"/> Yes	<input type="checkbox"/> No

The above checklist is to be used as a guide only. Please contact My Pool Safety Inspector for any specific advice you may require before your pool inspection.





# POOL INSPECTION CHECKLIST (NSW)

Waterfront Properties

Built/Installed with Door & Window as Barrier Before 01/07/2010

## DOORS

There is a latch on the door at least 1500mm above floor level on every door entering the pool area?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
There are no pet doors or openings to the pool area greater than 100mm?	<input type="checkbox"/> Yes	<input type="checkbox"/> No

## WINDOWS

The windows can only open to a maximum of 100mm? <b>OR</b>	<input type="checkbox"/> Yes	<input type="checkbox"/> No
The windows are totally covered by bars or a metal screen? <b>OR</b>	<input type="checkbox"/> Yes	<input type="checkbox"/> No
The height from the sill of the lowest opening panel of a window (to the pool area) is at least 1800mm from the floor?	<input type="checkbox"/> Yes	<input type="checkbox"/> No

The above checklist is to be used as a guide only. Please contact My Pool Safety Inspector for any specific advice you may require before your pool inspection.

[My Pool Safety Inspector Pty Ltd - Brisbane](#) | [Gold Coast](#) | [Sydney](#)

[www.mypsi.com.au](http://www.mypsi.com.au) | [email@myspi.com.au](mailto:email@myspi.com.au)

# POOL INSPECTION CHECKLIST (NSW)

Waterfront Properties

Built/Installed with a Pool Fence After 01/07/2010

POOL FENCE		
Is your pool fence at least 1200mm high all the way around the pool area?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
If a boundary fence forms part of the pool fence: Pools built before 01/09/2008 - it must be at least 1200mm high? Pools built after 01/09/2008 - it must be at least 1800mm high?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Are the gaps between the bottom of the fence and the ground no greater than 100mm?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
No potential hand holds or foot holds within 900mm of the top of the pool fence in any direction?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Are the gaps between the pool fence vertical rails or bars no greater than 100mm apart?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
If your pool fence has mesh or perforated material, are the holes no greater than 13mm?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Is your pool fence in good repair and fixed securely, with no damages?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
POOL GATES		
Does the pool gate open outwards away from the pool?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Does the pool gate self-close and self-latch from all open positions? The gate latch must be working well so that the gate is secure and, once closed, can't be pulled open.	<input type="checkbox"/> Yes	<input type="checkbox"/> No
If gate latch is on the outside, is the latch lever at least 1500mm above ground level?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
If gate latch is on the inside, is the latch lever at least 1200mm above ground level and at least 150mm below the top of the gate?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Are you aware that it is dangerous and against the law to prop the gate open?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
OTHER		
Is there a compliant CPR sign which can be easily read from a distance of 3 metres?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Your pool fence must be clear of any objects such as BBQs, trees, rocks, shrubs and deckchairs that could help a small child climb over the fence?	<input type="checkbox"/> Yes	<input type="checkbox"/> No

The above checklist is to be used as a guide only. Please contact My Pool Safety Inspector for any specific advice you may require before your pool inspection.

# POOL INSPECTION CHECKLIST (NSW)

## Indoor Pools

DOORS		
There is a latch on the door at least 1500mm above floor level on every door entering the pool area?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Doors open away from the pool area and are self-latching?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
There are no pet doors or openings to the pool area greater than 100mm?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
There are no wall openings greater than 100mm?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Is there a compliant CPR sign which can be easily read from a distance of 3 metres?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
WINDOWS		
The windows can only open to a maximum of 100mm? <b>OR</b>	<input type="checkbox"/> Yes	<input type="checkbox"/> No
The windows are totally covered by bars or a metal screen? <b>OR</b>	<input type="checkbox"/> Yes	<input type="checkbox"/> No
The height from the sill of the lowest opening panel of a window (to the pool area) is at least 1800mm from the floor?	<input type="checkbox"/> Yes	<input type="checkbox"/> No

The above checklist is to be used as a guide only. Please contact My Pool Safety Inspector for any specific advice you may require before your pool inspection.

**My Pool Safety Inspector Pty Ltd - Brisbane | Gold Coast | Sydney**  
[www.mypsi.com.au](http://www.mypsi.com.au) | [email@mypsi.com.au](mailto:email@mypsi.com.au)



# POOL INSPECTION CHECKLIST (NSW)

## Spas

### The Spa has a Lockable Lid

#### LOCKABLE LID

The spa is covered by a child-resistant lockable lid?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Is there a compliant CPR sign which can be easily read from a distance of 3 metres?	<input type="checkbox"/> Yes	<input type="checkbox"/> No

The above checklist is to be used as a guide only. Please contact My Pool Safety Inspector for any specific advice you may require before your pool inspection.

**My Pool Safety Inspector Pty Ltd - Brisbane | Gold Coast | Sydney**  
[www.mypsi.com.au](http://www.mypsi.com.au) | [email@myspi.com.au](mailto:email@myspi.com.au)

# POOL INSPECTION CHECKLIST (NSW)

Spas

The Spa is Enclosed by a Pool Fence & Gate

POOL FENCE		
Is your pool fence at least 1200mm high all the way around the pool area?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
If a boundary fence forms part of the pool fence: Pools built before 01/09/2008 - it must be at least 1200mm high? Pools built after 01/09/2008 - it must be at least 1800mm high?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Are the gaps between the bottom of the fence and the ground no greater than 100mm?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
No potential hand holds or foot holds within 900mm of the top of the pool fence in any direction?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Are the gaps between the pool fence vertical rails or bars no greater than 100mm apart?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
If your pool fence has mesh or perforated material, are the holes no greater than 13mm?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Is your pool fence in good repair and fixed securely, with no damages?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
POOL GATES		
Does the pool gate open outwards away from the pool?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Does the pool gate self-close and self-latch from all open positions? The gate latch must be working well so that the gate is secure and, once closed, can't be pulled open.	<input type="checkbox"/> Yes	<input type="checkbox"/> No
If gate latch is on the outside, is the latch lever at least 1500mm above ground level?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
If gate latch is on the inside, is the latch lever at least 1200mm above ground level and at least 150mm below the top of the gate?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Are you aware that it is dangerous and against the law to prop the gate open?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
OTHER		
Is there a compliant CPR sign which can be easily read from a distance of 3 metres?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Your pool fence must be clear of any objects such as BBQs, trees, rocks, shrubs and deckchairs that could help a small child climb over the fence?	<input type="checkbox"/> Yes	<input type="checkbox"/> No

The above checklist is to be used as a guide only. Please contact My Pool Safety Inspector for any specific advice you may require before your pool inspection.