

POOL INSPECTION CHECKLIST (QLD)

POOL FENCE		
Is your pool fence at least 1200mm high all the way around the pool area?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Are the gaps between the bottom of the fence and the ground no greater than 100mm?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Are the horizontal rails on your pool fence no closer than 900mm apart?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Are the gaps between the pool fence vertical rails or bars no greater than 100mm apart?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
If your pool fence has mesh or perforated material, are the holes no greater than 13mm?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Is your pool fence in good repair and fixed securely, with no damages?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
POOL GATES		
Does the pool gate open outwards away from the pool?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Does the pool gate self-close and self-latch from all open positions?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Are the gate hinges at least 900mm apart or are non-climbable safety caps installed?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
If gate latch is on the outside, is the latch lever at least 1500mm off the ground and 1400mm above the top part of the lower horizontal railings?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
If gate latch is on the inside, is the latch lever at least 150mm below the top of the fence and covered with a 450mm radius shield on the outside?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
OTHER		
No climbable objects within 900mm on the outside and 300mm on the inside?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Is there a compliant CPR sign that is easily visible to anyone near the pool?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
No doors which provide direct access from the house to the pool area?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Windows in the pool area fitted with security screens or open no greater than 100mm?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Is your pool registered on the QBCC Pool Register?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Electrical earthing for spigots and metal posts within 900mm of pool edge?	<input type="checkbox"/> Yes	<input type="checkbox"/> No

The above checklist is to be used as a guide only. Please contact My Pool Safety Inspector for any specific advice you may require before your pool inspection.