



P.O. Box 40 • Federalsburg, MD 21632

Telephone: (800) 257-9559 • Fax: (866) 706-5260

RED BRASS NIPPLES LOW-LEAD COMPLIANCY

All of Trenton Pipe's red brass nipples are manufactured in accordance to the ASTM B687 standard. This standard requires that all red brass pipe used in the manufacturing process conform to ASTM B43 Alloy C230.

ASTM B43 Alloy C230 has a maximum allowable lead content of 0.05%. The lead content is well within the AB 1953 requirement of 0.25% maximum.

Dated: May 1, 2009

Sincerely,

A handwritten signature in black ink, appearing to read 'Stephen J. Holloway', is written over a thin, light-colored horizontal line.

Stephen J. Holloway
President
Trenton Pipe Nipple Company