



TEST REPORT

DATE: 02-10-2020

TEST NUMBER: 0263998

CLIENT	PID Floors
--------	------------

TEST METHOD CONDUCTED	ASTM D3359 Method B Test Method for Measuring Adhesion by Tape Test
-----------------------	---



DESCRIPTION OF TEST SAMPLE	
IDENTIFICATION	Foundation Line
CONSTRUCTION	Engineered Wood
REFERENCE	Grace


GENERAL PRINCIPLE

This method covers the procedures for assessing the adhesion of coating films to substrates by applying and removing pressure sensitive tape over cuts made in the film. Lattice pattern cuts are made in the film to the substrate, pressure sensitive tape is applied over the lattice and removed, and adhesion is evaluated and classified via Figure 1 of the test method.

TEST RESULTS

Three locations of testing were completed with results of all three tests exhibiting the properties set forth in test classification 4B (the edges of the cut are completely smooth; Less than 5% of the square of the lattice are detached).

APPROVED BY:



This report is provided for the exclusive use of the client to whom it is addressed. It may be used in its entirety to gain product acceptance from duly constituted authorities. This report applies only to those samples tested and is not necessarily indicative of apparently identical or similar products. This report, or the name of Professional Testing Laboratory Inc. shall not be used under any circumstance in advertising to the general public.